

## System component: LEVEL 2 CONTROL PANEL



- Control panel in compliance with EN 54-16
- Manual voice alarm trigger button (red)
- Voice alarm LED (red)
- Manual voice alarm reset button (black)
- Voice alarm silence button (green)
- Silence LED (green)
- Fault indication reset button (black)
- Model: 19", 1RU
- Prepared cutout for optional service socket

The panel is installed in access level 2 (limited access), i.e. access to mentioned functions is restricted to authorized personnel.

